

## Supplement - Revisions Following Public Comment

As a result of an internal review, the Department of Health Services (Department) proposes to amend Table 64449-B. The units should be “ $\mu$ S/cm” (micro Siemens per centimeter), with the letter "S" being a capital letter since a lower case "s" typically stands for the time unit “second”. The previous version noted the unit for specific conductance as “s/cm”, inadvertently leaving out the indication that the standard was “micro” units and possibility having the “s” be misinterpreted as seconds, rather than Siemens.